

Property	Unit	Limits		Test Method
		Minimum	Maximum	
Fatty Acid Methyl Ester (FAME) Content	%(V/V)	10	20	EN14078
Water Content	%(m/m)		0.026	EN ISO 12937
Sulfur Content	mg/kg		10	EN ISO 20846
Density at 15°C	Kg/m ³	820,0	860,0	EN ISO 3675
Cetane Number		51		EN ISO 5165
Polycyclic aromatic hydrocarbons	%(m/m)		8	EN 12916
Manganese Content			2	Pr EN 16576
Flash point	°C	>55.0	-	EN ISO 2719
Ash Content	%(m/m)	-	0.010	EN ISO 6245
Total Contamination	mg/kg	-	24	EN 12662
Oxidation Stability	H	20	-	EN 15751
Viscosity at 40°C	mm ² /s	2.000	4.620	EN ISO 3104
Distillation				
% (V/V) recovered at 250°C	%(V/V)		<65	EN ISO 3405
% (V/V) recovered at 350°C	%(V/V)	85		
95% (V/V) recovered at	°C		360	

Climate Dependent Requirements and related Test Methods

Property	Unit	Limits		Test Method
		Grade C*	Grade E **	
CFPP °C	°C	-5	-15	EN 116

*Argent will supply Grade C from 16th March to the 31st October inclusive.

**Argent will supply Grade E from 1st of November to the 15th March inclusive.

Comments: -

- The above table is taken from BS EN 16709.

Issue Status

If printed this document becomes an "uncontrolled copy" and will not be subject to update unless over stamped as a "Controlled Copy"

Page 1 of 1

Page	1
Revision	1
Document	Dieselite B10 to B20 Technical Specification Sheet
Effective Date	01/08/25

Page 1 of 1